

Test Report No. 1497/3

Date Issued: 29 June, 2010

Product: Compartments with protective devices tier 2:
Schneider Electric NSX100H MCCB
Schneider Electric NSX160H MCCB
Schneider Electric NSX250H MCCB
Schneider Electric NSX400H MCCB
Schneider Electric NSX630H MCCB
in DRC, Relec, V2 Switchboard solutions

Clients rating: $U_e = 415 \text{ V } 50 \text{ Hz}$
 $I_{cc} = 63 \text{ kA}$

Client: DRC Switchboards Pty Ltd
60 Dehavilland Road
Mordialloc Vic 3195
Australia

Nature of tests: Testing of outgoing circuits according to
Clause 8.2.3.2.3 a) of AS/NZS 3439.1:2002.

Result: Refer results herein.

Prepared by:



John Strugarek

NATA Approved Signatory:



Antony K. Milovac

Tested at: ITACS High Power

ITACS Head Office & EMC
4-6 Second Street,
Bowden, South Australia 5007
Postal PO Box 300
Hindmarsh, South Australia 5007
Telephone (08) 8346 8680
Facsimile (08) 8346 7072
Email: itacs@itacslab.com

ITACS High Power
27 Sheehan Road,
Postal PO Box 5140
Heidelberg West DC
Victoria 3081
Telephone (03) 9458 3988
Facsimile (03) 9458 3172

ITACS HAE
PO Box 7212
Wilberforce NSW 2756
Telephone/Facsimile:
(02) 4576 3189

ITACS (HK) Ltd.
Approval Safety Testing
Room 707, West 7/F, Building 201
Tai ran Road 4, Che gong miao
Industrial Estate,
Futian District, Shenzhen
P. R. C.
Telephone/Facsimile:
(0755) 8238 3913



ACCREDITATION No. 1700