

Test Report No. 1497/5

Date Issued: 29 June, 2010

Product: DRC, Relec, V2 Switchboard solutions test board.

Clients rating: Main horizontal busbar (12 - 40 mm x 6.3 mm) - 4000 A
Horizontal busbar (3 - 40 mm x 10 mm) - 1700 A
NS1600H 3 pole MCCB compartment G1 - 1150 A

Client: DRC Switchboards Pty Ltd
60 Dehavilland Road
Mordialloc Vic 3195
Australia

Nature of tests: Temperature Rise Test according to
Clause 8.2.1 of AS/NZS 3439.1:2002.

Result: Refer results herein

Prepared by:



John Strugarek

NATA Approved Signatory:



Antony K. Milovac

Tested at: ITACS High Power

ITACS[®]

International Testing and
Certification Services Pty. Ltd.

ABN 60 098 886 563

www.itacslab.com

This document is issued in accordance with
NATA's accreditation requirements.

Accredited for compliance
with ISO/IEC 17025

Technical Competence

NATA is a signatory to the ILAC
Mutual Recognition Arrangement
for the mutual recognition of the
equivalence of testing and
calibration reports.

World Wide Recognition

ITACS Head Office & EMC
4-6 Second Street,
Bowden, South Australia 5007
Postal PO Box 300
Hindmarsh, South Australia 5007
Telephone (08) 8346 8680
Facsimile (08) 8346 7072
Email: itacs@itacslab.com

ITACS High Power
27 Sheehan Road,
Postal PO Box 5140
Heidelberg West DC
Victoria 3081
Telephone (03) 9458 3988
Facsimile (03) 9458 3172

ITACS HAE
PO Box 7212
Wilberforce NSW 2756
Telephone/Facsimile:
(02) 4576 3189

ITACS (HK) Ltd.
Approval Safety Testing
Room 707, West 7/F, Building 201
Tai ran Road 4, Che gong miao
Industrial Estate,
Futian District, Shenzhen
P. R. C.
Telephone/Facsimile:
(0755) 8238 3913



ACCREDITATION No. 1700