

# Test Report No. 1497/6

Date Issued: 29 June, 2010

Product: DRC, Relec, V2 Switchboard solutions test board.

Clients rating: Vertical busbar tier 'E' (1 - 100 mm x 6.3 mm) with:  
NSX400H 3 pole MCCB compartment (D2) – 351 A  
NS400H 3 pole MCCB compartment (D3) – 351 A  
NSX630H 3 pole MCCB compartment (D4) – 501 A  
NSX630H 3 pole MCCB compartment (D5) – 501 A  
and spill current compartment (D6) – 501 A

Client: DRC Switchboards Pty Ltd  
60 Dehavilland Road  
Mordialloc Vic 3195  
Australia

Nature of tests: Temperature Rise Test according to  
Clause 8.2.1 of AS/NZS 3439.1:2002.

Result: Refer results herein

Prepared by:



John Strugarek

NATA Approved Signatory:



Antony K. Milovac

Tested at: ITACS High Power

**ITACS Head Office & EMC**  
4-6 Second Street,  
Bowden, South Australia 5007  
Postal PO Box 300  
Hindmarsh, South Australia 5007  
Telephone (08) 8346 8680  
Facsimile (08) 8346 7072  
Email: itacs@itacslab.com

**ITACS High Power**  
27 Sheehan Road,  
Postal PO Box 5140  
Heidelberg West DC  
Victoria 3081  
Telephone (03) 9458 3988  
Facsimile (03) 9458 3172

**ITACS HAE**  
PO Box 7212  
Wilberforce NSW 2756  
Telephone/Facsimile:  
(02) 4576 3189

**ITACS (HK) Ltd.**  
**Approval Safety Testing**  
Room 707, West 7/F, Building 201  
Tai ran Road 4, Che gong miao  
Industrial Estate,  
Futian District, Shenzhen  
P. R. C.  
Telephone/Facsimile:  
(0755) 8238 3913



ACCREDITATION No. 1700

# ITACS<sup>®</sup>

**International Testing and  
Certification Services Pty. Ltd.**

ABN 60 098 886 563

[www.itacslab.com](http://www.itacslab.com)

This document is issued in accordance with  
NATA's accreditation requirements.

Accredited for compliance  
with ISO/IEC 17025

**Technical Competence**

NATA is a signatory to the ILAC  
Mutual Recognition Arrangement  
for the mutual recognition of the  
equivalence of testing and  
calibration reports.

**World Wide Recognition**